

Site Bid: 149220778

Date: 5/15/2023



Penetration - Improper installation (Emergency)

Quantity: 1 EA

Deficiency:

The existing penetration was flashed with improper materials

Corrective Action:

Remove the existing materials and flash the penetration with the manufacturers approved materials and installation procedure.



Penetration - Improper installation (Emergency)

Quantity: 1 EA

Deficiency:

The existing penetration was flashed with improper materials

Corrective Action:

Remove the existing materials and flash the penetration with the manufacturers approved materials and installation procedure.

Site Bid: 149220778

Date: 5/15/2023



No sealant under screws (Emergency)

Quantity: 4

Deficiency:

We will need to pull the neoprene screws out and put mastic under flashing and then reattach with new neoprene screws. The sections are 12 foot long and there is four of them.

Corrective Action:



ROOFING PLUS, INC.
COMMERCIAL & GOVERNMENT

RC Hospitality
Grand Panama Beach Resort
11807 Front Beach Rd
Panama City Beach, FL 32407



Description **Amount**

☒ Repairs \$4,710.00

Terms and Conditions

Payment is due upon completion of work unless specified in another agreement. An invoice will be sent with documentation of work performed.

Work Authorization

I hereby authorize the work indicated in this document. I understand the minimum cost per service work order is \$500.

Site Bid No.

149220778

Signature: _____ Date: _____

Printed Name: _____ PO#: _____



Duro-Last Platinum Contractor
1525 University Drive
Auburn, GA 30011