
Coastal Kenny's Pool Repair

Titus Booth

Property: Grand Panama Beach Resort

Front Beach Road

Panama City Beach, FL 32407

Proposal – Pool Repairs (Tower 1 & Tower 2)

Tower 1 Repairs

1. TR140 Sand Filter – Sand Replacement

Replace sand in the TR140 sand filter (only one of three units not replaced in recent years).

- Sand: \$1.00 per pound
- Estimated total: \$1,100.00
- Dump/disposal fee: \$0.00

2. Chlorinator Replacement

Replace chlorinator to restore proper system flow.

- Total: \$300.00

3. Cartridge System Leak Repairs

Repair two leaks in the cartridge section of the system.

- Total: \$300.00

Tower 1 Subtotal: \$1,700.00

Tower 2 Repairs

1. TR100 Sand Filter – Sand Replacement (2 Units)

Replace sand in two TR100 filters.

- (2) Units at \$500.00 each: \$1,000.00
- Dump/disposal fee: \$375.00

2. Plumbing & Flow System Improvements

Redo inlet and outlet lines to the heater, repair active leak, reduce approximately 70% of elbows to improve flow, and install proper pressure gauges, flow meters, and valves.

- Total: \$1,100.00

3. Pool Lighting Replacement

Install new 12-volt corded Intelli pool light including labor.

- Total: \$1,525.00

4. Spa Light & Gasket Replacement

Install new 12V LED spa light and replace gasket.

- Total: \$350.00

Tower 2 Subtotal: \$4,350.00

Total Project Cost

Grand Total (Tower 1 + Tower 2): \$6,050.00
